



- 1) IN-LINE WYE FOR EXISTING STRUCTURES
- 2) WYE SADDLE FOR OTHER SERVICES.
- 3) BACKFILL UNDER WYE TO BE SCREENED ROCK OR CLASS 6 AGGREGATE, 95% COMPACTION DENSITY PER ASTM D-692.
- 4) MINIMUM COVER - 5 FEET.

STANDARD SEWER SERVICE CONNECTION DETAIL

N.T.S.

SEWER SERVICE
CONNECTION DETAIL

TOWN OF NEW CASTLE

NOT TO SCALE

DWG: SW-40