



- 1) PAVEMENT REPLACEMENT SHALL MEET EXISTING THICKNESS AND KIND WITH THE FOLLOWING MINIMUMS: ASPHALT SURFACING = 3" MIN., AGGREGATE BASE COURSE = 8" MIN.
- 2) FOR UNPAVED SURFACES, BASE COURSE REPLACEMENT SHALL MEET EXISTING THICKNESS WITH THE FOLLOWING MINIMUMS: AGGREGATE BASE COURSE = 12" MIN.
- 3) DIRT / TOPSOIL PLACEMENT SHALL MEET EXISTING THICKNESS AND KIND WITH THE FOLLOWING MINIMUMS: 4" TOPSOIL.
- 4) SELECT MATERIAL AS FOLLOWS: 6" MAXIMUM SIZE.
(ROCKS TO BE PLACED SO THAT NO VOIDS ARE CREATED.)
- 5) DETAIL ABOVE FOR "DRY TRENCH" CONDITIONS. FOR UNSTABLE OR "WET TRENCH" CONDITIONS PROVIDE A MINIMUM OF 4" OF 1 1/2" SCREENED ROCK UNDER BEDDING MATERIAL WITH FILTER FABRIC PLACED BELOW AND ABOVE THE SCREENED ROCK.

TRENCH CROSS SECTION

SCALE: 3/4" = 1'-0"

STANDARD SEWER
MAIN TRENCH SECTION

TOWN OF NEW CASTLE

NOT TO SCALE

DWG: SW-50