



- NOTES: 1) ALL JOINTS FROM MAIN TO HYDRANT SHALL BE HARNESSSED MECHANICAL JOINTS OR FLANGED JOINTS.
 2) HYDRANT, VALVE AND FITTINGS TO BE 250 P.S.I. RATED.
 3) POLYETHYENE WRAP SHALL COVER D.I.P. ASSEMBLY FROM HYDRANT BASE TO WATER MAIN.
 4) ALL HYDRANT LEAD PIPING TO BE 6" D.I.P.
 5) CENTERLINE OF HYDRANT TO BE 4'-0" FROM BACK OF CURB UNLESS OTHERWISE NOTED.
 6) FOR FIRE HYDRANTS ON END OF WATER LINE.
 7) CARE SHOULD BE TAKEN TO ASSURE THAT WEEP HOLE REMAINS FREE DRAINING.

FIRE HYDRANT ASSEMBLY INSTALLATION DETAIL

FIRE HYDRANT
SETTING DETAIL

TOWN OF NEW CASTLE

NOT TO SCALE

DWG: WA-20